



Prüfzentrum für Bauelemente


Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows
 Rollläden · shutters
 Türen + Tore · doors
 Fassaden · curtain walling
 Baubeschläge · building hardware

TEST CERTIFICATE NO. 11/09-A325-Z1

Initial type testing of performance according EN 13241-1 : 2003 "Industrial and commercial garage doors and gates – Product Standard – Part 1: Products without fire resistance or smoke control characteristics"

Customer Özbosan Boru-Profil Endüstrisi Otomatik Kepen Sist. ve Lamine Ahşap Pazarlama İth.İhr.San.Tic.Ltd.Şti.
 Fatih mahallesi Çamlık cad. No:24
 35414 Sarnıç / Gaziemir / İzmir



Product type 100%PES, Power Operated Industrial Door

Product name B6000

Dimension Total outside dimensions (W x H) max. 2620 mm x 2950 mm

Panel SIOEN B6000

Motor MTZ-FU 05-4-135 FU-E KU 230V/3Ph AWG.

Classification according to test report No. 11/09-A325-B1 from November 04, 2011:



EN 12427	Air Permeability	EN 12426	Class 0
EN 12489	Water tightness	EN 12425	Class 0
EN 12444	Resistance to wind load	EN 12424	Class +1/-1

Validity Period of validity of EN 13241-1 : 2003

Dipl. Ing.(FH) Rüdiger Müller
 Head of Institute / Notified Test Body November 04, 2011



Dipl.-Ing.(FH) Christoph Geiger
 Responsible Official

PFB GmbH & Co. Prüfzentrum für Bauelemente KG
 Lackermannweg 24
 D-83071 Stephanskirchen (bei Rosenheim)
 Gesellschafter M. Demmel, R. Müller, A. Urban
 AG Traunstein HRA 8871

Telefon +49 (0) 80 36 / 67 49 47 - 0
 Telefax +49 (0) 80 36 / 67 49 47 - 28
 www.pfb-rosenheim.de
 info@pfb-rosenheim.de

Sparkasse Rosenheim
 Bankleitzahl 711 500 00
 Kontonummer 500 556 741
 Steuer-Nr. 156/172/13009
 USt-IdNr. DE245353602

